FOR:

ADDRESS:

CAPTAIN JAMES A. LOVELL FEDERAL HEALTH CARE CENTER


100% ISSUE FOR BID SET MAY 17, 2013

VA# 556-12-127 BANCROFT # 12-119

3001 GREEN BAY ROAD NORTH CHICAGO, IL 60064

PROJECT DESCRIPTION:

BUILDING 133 OR-GI-ON 2ND AND 3RD FLOORS RENOVATIONS





DEDUCT ALTERNATE & SCOPE- CHCOLOGY FREMATIC TUBE SYSTEM THE OF WORK DESCRIPTION OF WORK TO BE EXCEPTED. THE OF

A	PPLICABLE CODES AND STANDARDS	FIRE RESISTIVE RATINGS (MOST RESTRICTIVE APPLIES)			BUILDING DATA			
	VA DIRECTIVES, DESIGN MANUALS, MASTER SPECIFICATIONS, VA	BUILDING	BUILD	ING 133 & 133CA	BUILDING BUILDING		NG 133 & 133CA (FULLY SPRINKLED)	
	NATIONAL CAD STANDARD APPLICATION GUIDE, AND OTHER GUIDANCE ON THE TECHNICAL INFORMATION LIBRARY (TIL)	USE (FIRE AREA)		HOSPITAL	USE (FIRE AREA)	HOSPITAL		
	(HTTP://WWW.CFM.VA.GOV/TL/).	APPLICABLE CODE	IBC, 2012	NFPA 101, 2012	APPLICABLE CODE	IBC, 2012	NFPA 101, 20	12
	INTERNATIONAL BUILDING CODE (BC) 2012				USE GROUP	I-1.1; INSTITUTION		
	NFPA 101 LIFE SAFETY CODE 2012	AUTOMATIC SPRINKLER SYSTEM REQUIREMENT STANDPIPE SYSTEM REQUIREMENT	YES CLASS II	YES		2-HOUR AREA	HEALTHCARE 2-HOUR AREA	
		EXTERIOR BEARING WALLS (N.A.)	4-HOUR	1		SEPARATION PARTI	TION SEPARATION F	ARTITION
	NFPA NATIONAL FIRE CODES WITH THE EXCEPTION OF NFPA 5000 AND NFPA 900	SUPPORTING MORE THAN ONE FLOOR	-	3-HOUR	CONSTRUCTION TYPE	TYPE I-F.R.	TYPE I (332)	
	3000 AND NETA 900	SUPPORTING ONE FLOOR ONLY	-	3-HOUR	ALLOWABLE HEIGHT	UNLIMITED	NOT LIMITED	
	OCCUPATIONAL, SAFETY AND HEALTH ADMINISTRATION (OSHA)	SUPPORTING ROOF ONLY	I-	3-HOUR	AUTOMATIC SPRINKLER INCREASE	(308.2.1)		
	STANDARDS.	INTERIOR BEARING WALL (N.A.) SUPPORTING MORE THAN ONE FLOOR	2-HOUR	3-HOUR	MAXIMUM ALLOWABLE HEIGHT ALLOWABLE AREA	UNLIMITED UNLIMITED	NOT LIMITED NOT LIMITED	
	VA SEISMIC DESIGN REQUIREMENTS, H-18-8	SUPPORTING ONE FLOOR ONLY	-	2-HOUR	MULTI-STORY AREA INCREASE	UNLIMITED	NOT LIMITED	
	TH SESSION DESIGN RECORDERENTS, IT-10-0	SUPPORTING ROOF ONLY	1	2-HOUR	10% ALLOWABLE TABULAR AREA			
	NATIONAL ELECTRICAL CODE (NEC) 2011	COLUMNS, BEAMS, GIRDERS, TRUSSES	3-HOUR	L moon	STREET FRONTAGE			
		SUPPORTING MORE THAN ONE FLOOR	-	3-HOUR	10% AUTOMATIC SPRINKLER			
	NATIONAL STANDARD PLUMBING CODE (NSPC) 2012	SUPPORTING ONE FLOOR ONLY	-	2-HOUR	MAXIMUM ALLOWABLE AREAS, F. /FLR.)	UNLIMITED		
	ASME BOILER AND PRESSURE VESSEL CODE 2010	SUPPORTING ROOF ONLY	-	2-HOUR	MAXIMUM ALLOWABLE ARE(S.F./TOTAL BLDG.)	UNLIWITED	NOT LIMITED	
		FLOOR CONSTRUCTION	2-HOUR	2-HOUR	ACTUAL HEIGHT	4 ST. / "-"		
λ.	ASME CODE FOR PRESSURE PIPING	ROOF CONSTRUCTION EXTERIOR NON-BEARING WALLS	2-HOUR	1.5-HOUR	ACTUAL AREA (BUILDING FOOTPRINT)(1st FLOOR)	103,695.8 SF		
ı.	ARCHITECTURAL RARRIERS ACT ACCESSIBILITY STANDARDS	< 5 FEET	1-HOUR					
	(ABAAS) INCLUDING VA SUPPLEMENT, BARRIER	< 10 FFFT	1-HOUR HAZARDOUS AREA SEPARATION PROTECTION		ION			
	FREE DESIGN GUIDE (PG-18-13)	S= 30 FEET	1-HOUR		NAZARDOUS AREA SEPARATION PROTECTION			
	BUILDING CODE REQUIREMENTS FOR REINFORCED CONCRETE.	> 30 FEET	0-HOUR (>40ft, SEP.)	0-HOUR (SEP. DIST.)	AND THE COOL	BC, 2012	MEPA 101, 2012	MFPA 99, 2012
•	AMERICAN CONCRETE INSTITUTE AND	HORIZONTAL EXIT	2-HOUR	2-HOUR	ANESTHETIZING LOCATIONS		REFER TO NEPA 99	1-HOUR
	COMMENTARY (ACI 318)	FIRE WALLS / PARTY WALLS	2-HOUR	-	BOILER AND FUEL - FIRED EQUIPMENT		1-HOUR	1-HOUR, NOTE
		FIRE SEPARATION ASSEMBLIES			COOKING FACILITIES		REFER TO NFPA 96	
ARA COMPLIANCE		exits and shafts <4 stories	2-HOUR, NOTE 1	1-HOUR	GIFT SHOP - NOT HAZARDOUS < 500 SF		0-HOUR, NOTE 1	
_		EXITS AND SHAFTS => 4 STORIES MORTO LISE AND OTHER SEPARATIONS	2-HOUR, NOTE 1	2-HOUR 2-HOUR	GIFT SHOP - HAZARDOUS		1-HOUR, NOTE 1	
PI	ER CBC CHAPTER 18-11-1117.3.4 AND ICC/ANSI-A117.1- 2003 THE	MIXED USE AND OTHER SEPARATIONS PARTITIONS: PERMANENT	1-HOUR (Non-Comb.)	2-HOUR	LABORATORIES USING FLAMMABLES - NOT SEVERE	1-HOUR	1-HOUR, NOTE 1	1-HOUR, NOTE
FC	DLLOWING COMPLY FULLY:	FIRE PARTITIONS: CORRIDORS	1-HUUK, (Non-Comb.)	-	LABORATORIES USING FLAMMABLES - SEVERE		REFER TO NFPA 99 1-HOUR	1-HOUR 1-HOUR, NOTE
1.	ACCESSIBLE MAIN ENTRY	WITH AUTOMATIC SPRING FR SYSTEM	0-HOUR SMOKE TIGHT	0-HOUR SMOKE TIGHT	LAUNDRIES > 100 SF	1-HOUR	1-HOUR NOTE 1	1-HOUK, NOTE
"		DOORS	0-HOUR	0-HOUR	MEDICAL GAS ROOMS / STORAGE ROOMS	1	REFER TO NEPA 99	1-HOUR
2.		SMOKE BARRIER (PARTITION)	1-HOUR	1-HOUR	PAINT SHOP - NOT SEVERE	1-HOUR	1-HOUR	1-HOUR, NOTE
	& ACCESSIBLE ELEVATOR TO 2nd AND 3rd FLOORS	SMOKE COMPARTMENT SIZE	22,500 SF / 150" MAX.	22,500 SF / 200° TR.	PHYSICAL PLANT MAINTENANCE SHOP	1-HOUR	1-HOUR	1-HOUR, NOTE
3.	. ACCESSIBLE MEN'S AND WOMEN'S TOLET ROOMS ARE ON 2nd AND	DOORS	45-MN	45-MN	REPAIR AND HANDICRAFT SHOP		1-HOUR, NOTE 1	1-HOUR
3	rd FLOORS	TRAVEL DISTANCE TO EXIT			SOILED LINEN ROOMS	1-HOUR	1-HOUR	1-HOUR, NOTE
4.	ACCESSIBLE HI-LO DRINKING FOUNTAINS ARE ON 2nd AND 3rd	FROM ROOM DOOR TO EXIT FROM ANYWHERE IN BOOM TO EXIT	200*	150'	STORAGE ROOMS > 50 SF < 100 SF		1-HOUR, NOTE 1	1-HOUR, NOTE
	. ACCESSIBLE M-LO DRINKING FOUNTAINS ARE ON 2ND AND 3RD	INCREASE WITH AUTOMATIC SPRINKLER SYS		NCLUDED.	STORAGE ROOMS > 100 SF	1-HOUR 1-HOUR	1-HOUR 1-HOUR	1-HOUR, NOTE 1-HOUR, NOTE
		WITHIN A SUITE OF ROOMS TO EXIT DOOR		100'	TRASH COLLECTION ROOMS	1-HOUR	1-HOUR	1-HOUR, NOTE
5. Bi	. ALL CONTROLS AND OPERABLE PARTS FULLY COMPLY AND ARE ETWEEN 15" AND 48".							
6. LC	. ALL SIGNAGE COMPUES — IS OF BRAILLE AND TACTILE AND IS DCATED ON THE DOOR HANDLE SIDE OF DOOR. INSTALLED AT PPROPRIATE HEIGHT AND DISTANCE FROM DOOR FRAME.							
10	. ALL STORAGE AREAS FULLY COMPLY - CLOSET RODS, WALL OUNTED CABINETRY AND ANY TYPE OF SHELVING IS AT 48" AFF TO UP OF ROTTOM SHELF.							

